



3- PHASE TRANSFORMER KVA	DIMENSIONS IN INCHES					REINFORCING BARS				
	A	B	C	D	E	MK1	MK2	MK3	MK4	MK5
750, 1000	104	100	10	54	8	12 #4 98'	6 #4 19'	6 #4 94'	7 #4 66'	4 #4 29'

NOTES

- 1 CONCRETE TESTING, 4000 POUNDS PER SQUARE INCH; 4/ TO 6/ ENTRAINED AIR, 3/4 MAXIMUM SIZE AGGREGATE
- 2 REINFORCING STEEL ASTM-A615 GRADE 60, PLACE APPROX 6 OC EACH WAY AND SECURELY TIED TOGETHER
- 3 MINIMUM CONCRETE COVER REINFORCING STEEL 2 INCHES UNLESS NOTED
- 4 WOOD FLOAT FINISH LEAVING NO DEPRESSIONS

CENTRAL NEW MEXICO ELECTRIC COOPERATIVE INC.	ENGINEERING MANAGER	THREE PHASE TRANSFORMER CONCRETE PADS 500, 1000 KVA	
	ENGINEER GF.S		
	CAD GF.S	DATE 1/9/98	UMI-6C_L 750, 1000 KVA